

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1076:124

Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Kidde-Fenwal Inc., 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000 *Fax (508) 881-1773

DESIGN: Models CSX and CVX electric bells.

Model CSX10-115-R, CSXG10-115-R, CSX10-24-R, CSXG10-24-R.
Model CVX10-115-R, CVXG10-115-R.

No letter: for indoor use with no guard; G: for outdoor with wire guard.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electric bells for use with separately listed electrically compatible fire alarm control units. Suitable for Class I, Group B, C, and D; Class II, Group F and G hazardous locations.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7135-0785:130

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager